

1704.3.4, 1704.6.2

Special Inspection for the Bracing of Trusses

CHANGE TYPE: Addition

CHANGE SUMMARY: Two new sections have been added to require that the special inspector verify that temporary and permanent bracing are installed in accordance with the approved truss submittal package for both cold-formed steel and wood trusses.

2009 CODE: 1704.3.4 Cold-formed Steel Trusses Spanning 60 Feet or Greater. Where a cold-formed steel truss clear span is 60 feet (18 288 mm) or greater, the special inspector shall verify that the temporary installation restraint/bracing and the permanent individual truss member restraint/bracing are installed in accordance with the approved truss submittal package.

1704.6.2 Metal-plate Connected Wood Trusses Spanning 60 Feet or Greater. Where a truss clear span is 60 feet (18 288 mm) or greater, the special inspector shall verify that the temporary installation restraint/bracing and the permanent individual truss member restraint/bracing are installed in accordance with the approved truss submittal package.

CHANGE SIGNIFICANCE: Special inspection requirements for cold-formed steel trusses and metal-plate connected wood trusses with spans of 60 feet or more have been added. The special inspector must verify that temporary and permanent bracing are installed in accordance with the approved truss submittal package. The language used in Section 2210.3 for cold-formed steel trusses also was coordinated with the language used in Section 2303.4 for wood trusses.



Courtesy of Steel Framing Alliance